



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8136CL0493
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Peštan d.o.o. 1300 Kaplara 189, RS-34301 Bukovik
Distributor <i>Vertreiber</i>	Peštan d.o.o. 1300 Kaplara 189, RS-34301 Bukovik
Product Category <i>Produktart</i>	Plastic pressure tubes for supply pipelines: PE pipes (monolayer) for water supply, size group 1 (8136)
Product description <i>Produktbezeichnung</i>	pipe made of plastic PE-HD (PE 100) for the drinking water supply
Model <i>Modell</i>	PE-HD-Rohr "Pestant"
Test reports <i>Prüfberichte</i>	Laboratory control test: V197/25-1.1 from 22.07.2025 (IMA) Type testing: K 10 0783.1+K 10 0783.2 from 15.12.2010 (IMA)
Test basis <i>Prüfgrundlagen</i>	DVGW GW 335-A2 (01.11.2005) DVGW GW 335-A2/B1 (01.12.2010)



Date of Expiry / File No. 15.12.2030 / 25-0960-WNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

30.10.2025 Le A-1/2 *A. W. T.*
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvqw-cert.com
www.dvqw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PE-HD-Rohr "Pestan"	Manufacturing group: 14	diameters: up to 63 mm

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Suitability for drinking water hygiene is verified with a "Hygiene confirmation of conformity" in accordance with the currently valid legal basis.

The logo for DVGW CERT, featuring a stylized blue icon above the text "DVGW" and "CERT" separated by a horizontal line.